

Policy No.: OS001	Approved by: Mark Cavanaugh
Title: Energized Electrical Safety	Date: 6/15/2020
Revision No.: 6	Page 24 of 31
Prepared by: Mike Liberty	

Appendix G: Inspection Schedule for Rubber Insulating Equipment

Type of Equipment	When to Test
Rubber insulating line hose	Upon indication that insulating value is suspect
Rubber insulating covers	Upon indication that insulating value is suspect
Rubber insulating	Before first issue and every 12 months thereafter (*)
Rubber insulating gloves	Before first issue and every 6 months thereafter (*)
Rubber insulating sleeves	Before first issue and every 12 months thereafter (*)
Leather Protectors	Before first issue and every 12 months thereafter

(*) – If the insulating equipment has been electrically tested but not issued for service, it may not be placed into service unless it has been electrically tested within the previous 12 months.