

Appendix II

Commissioning Form

Building:

Room:

REQUIREMENT	YES / NO
Project:	
Sensors located near each point of egress?	
Sensor 4 – 6 feet above floor or per manufacturer?	
Sensor free of obstruction (2-3 feet)?	
Panel located outside of monitored area?	
Panel mounted 4 – 5 feet above floor?	
Alarm points per Table 1?	
Strobe and annunciator outside point(s) of egress?	
Different than area fire alarm and CO?	
Alarm connected to bldg. mgmt. system?	
Signage is posted in the immediate area of panel/strobe?	

Comments:

Name of EH&S personnel:

Date: